

TECHNICAL PERFORMANCE INDICATORS FOR WIND ENERGY



Background : The performance indicators proposed here are the results of the work of the WEC Committee on the Performances of Generating Plants (PGP). Their objective, through benchmarking, cross-comparisons, intercomparisons, and eventually databases, is to help to compare the merits and demerits of various technologies, identify and analyse their eventual weaknesses, and thus lead to improvements in their performances and finally contribute to a more efficient and vigorous development of Renewable Energies.

| Proposed Technical Indicators | Definitions and comments |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Capacity Factor (%) = Total energy production during the nominal period Potential energy production during the period Specific energy production (kWh/m ²) = Total energy production during the nominal period Swept rotor area Equivalent full load hours (h) = Annual energy production Rated power Availability Factor (%) = Total hours of operation of plant during the period x 100 Total length of the period (hours) Wind conditions during the period (m/s) = Average wind speed and wind speed distribution | Nominal period (hours) = complete period covered by the report, usually one year Total energy production (kWh) = energy delivered at the connecting point during the monitoring (nominal) period, usually one year Potential energy production (kWh) = rated power x monitoring (nominal) period, usually one year Specific energy production (kWh) is also often called «energy yield» or «energy productivity», and is very much dependant on the rated power of the turbines. Period of non availability (h) = period during which the plant is not functionning. This can be scheduled (maintenance) or not (failure, malfunction). The availability usually ranges around 95% for wind farms. Wind conditions are very important to be able to compare the performances of plants (see next page) |

Remarks:

- Other general information must of course be provided for further analysis and fair comparisons : plant size, cycle of operation, age, vintage, type of turbines, etc ... Life time and return time (number of years of production of electricity needed for implementation of the plant) should also be provided when available.
- The notion of « availability non availability » is a rather complex notion. One should refer to the norm IEC 61400-25 for more details and standardization of the definitions.

The hereunder figure shows the Monthly Capacity Factor of the wind turbines

January 1993.

Complementary indicator to be used when possible = % predicted versus really produced electricity (24h, 48 h, 1 week in advance)



The actual monthly energy delivery achieved by all observed plants is thereby related to the theoretically maximum total monthly production with continuous full load, whereby 125,000 monthly energy delivery reports from the years 1990-1998 were available. The average values of the individual months (and therefore the expectation values) range from 15% in July, to 32% in January. According to the general weather situation and the annual available wind, deviations can be noted which range from the mini-mum value in August 1997 with 7% capacity factor, to the maximum value of 450/

edf





| World Energy Council SOCIOLOGICAL CONSEL MONDIAL DE L'ENERGIE FOR | | | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|
| WIND I | ENERGY | | | |
| Proposed Sociological Indicators | Samples and comments | | | |
| - Jobs created by the plant (n/MW) : Nj = number of jobs (direct / indirect) created by a 1 MW power plant for the different steps : manufacture, installation, operation and maintenance. | Beware of subsidies in some countries which can distor the data and prevent meaningful comparisons. A distinction must be made between job-years for manufacturing and installation on one hand, and jobs for O&M on the other hand, especially when the manufacturer is not in the country of installation. A European study of 1999 assumes that 17 job-years or employment are created for every MW of wind energy capacity manufactured, and a further 5 job – years for the installation of every MW, bringing the total to 22 job years. The latest update of <i>Wind Force 12</i> (EWEA, 2003a suggests that the feasible number of jobs created in the wind industry worldwide by 2020 will be 1.8 million. | | | |
| - Providing access to electricity : Na = number of households / total number of people having now access to the electricity produced by a 1 MW plant, and who would not have such access if another type of plant were to be built (grid connected). | <i>Recall</i>: we have chosen in the study to focus only on grid connected plants. In developing countries, isolated wimt turbines may bring power to people who may not otherwise, have access to electricity at all without them. WindPower Denmark : 1 MW wind energy provide electricity to 500 to 800 households in Europe. Edens Italy : a wind plant rated 1 MW can provide electricity for 1000 houses (without heating) | | | |
| - Industrial Safety Accident Rate : SAR = number of accidents for all utility personnel permanently assigned to the plant (contractor personnel not included), that result in one or more days away from work (excluding the day of the accident) or one or more days of restricted work (excluding the day of the accident), or fatalities, per 1,000,000 man-hours worked. | This indicator is already widely used for othe conventional types of power plants (nuclear, fossil-fired etc). The purpose of this indicator is to monitor progress i improving industrial safety performance for all utility personnel permanently assigned to the utility's staff. This indicator was chosen as the personnel safety indicator over other indicators, such as injury rate or severity rate, because the criteria are clearly defined utilities currently collect this data, and the data are the least subjective. | | | |
| * Institut für Solare Energieversorgungste Königstor 59, D-34119 Kassel, Gern Tel : +49 (0) 561 7294-0 Fax : +49 | ck Street, London WIR 6LE, UK. 20) 7734 5926 E-mail: info@worldenergy.org chnik at http://www.iset.uni-kassel.de | | | |



eD

Remark:

CESI

PV systems of different configurations and at different locations can be readily compared, by evaluating suitable normalised system performance indicators. The proposed indicators are already commonly used by PV system operators and are stated by different organisations (see: IEC 61742 *Photovoltaic system performance monitoring: Guidelines for measurement, data exchange and analysis,* 1998; IEA PVPS Task II *Operational performance of PV power systems: Measurements and monitoring approaches,* 1998).

Sample Applications

The following examples show data collected from some typical power plants :

In Italy :

Serre PV Central Station (3.3 MWp)

| Y ear | 1995 | 1996 | 1997 | 1998 | 1999 |
|----------------------------------------|------|------|------|------|------|
| R efer en ce Yield, Y R [k W h/m ²] | 1674 | 1641 | 1784 | 1704 | 1723 |
| [h/d] Boufour on co Datio BB | 4.58 | 4.50 | 4.89 | 4.67 | 4.72 |
| Performance Ratio, PR [%] | 48.0 | 70.4 | 68.7 | 68.7 | 68.6 |

Bovisa PV roof top plant (3 kWp) CESI PV roof top plant (3 kWp)

Caglian PV roof top plant (3 kWp)

| Year | 1999 | Year | 1999 | Year | 1999 |
|------------------------------------------|------|---------------------------------|------|--------------------------------------------|------|
| Reference Yield, Y _R [h/d] | 3.75 | Re fer ence Y ield, YR [h/d] | 3.32 | R efe rence Yield, Y _R [h/d] | 4.03 |
| Final Yield, Yf [h/d] | 2.44 | Final Yield, Yf [h/d] | 2.35 | Final Yield, Yf [h/d] | 3.15 |
| Performance Ratio, PR [%] | 65.0 | Performance Ratio, PR [%] | 70.9 | Per formance Ratio, PR [%] | 78.2 |

In Egypt : experimental unit of 0.11 kW p PV water pumping station

| Year | July 1996 |
|--------------------------------------|-----------|
| R eference yield Y_R | 4.36 |
| [h/d] Array Yield YA | 3 |
| [h/d] Final Yield Y _f | 1.086 |
| [h/d] Performance Ratio PR | 25% |
| [%] | |

<u>In Japan</u> :

Sa ijyo project 1000 kWp

| Year | 2000 |
|--------------------------------------|------|
| Reference yield Y_R | 3.84 |
| [h/d] Array Yield Y [h/d] | 3.56 |
| Final Yield Y _f | 3.32 |
| [h/d] Performance Ratio PR | 86% |
| | 8070 |





| PERFORMANCE IN PHOTOVOLT | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Proposed Sociological Indicators | Samples and comments |
| - Jobs created by the plant (n/MW) : Nj = number of jobs (direct / indirect) created by a 1 MW power plant for the different steps: manufacture, installation, operation and maintenance. | Beware of subsidies in some countries which car distort the data and prevent meaning fur comparisons. A distinction must be made between job-years for manufacturing and installation on one hand, and jobs for O&M on the other hand, especially when the manufacturer is not in the country of installation Estimate by CEA-France 2003 : 20 jobs per produced MW, 30 jobs per consumed MW SEIA (Solar Energy Industry Association – USA → 3,800 jobs created for every \$ 100 million of PV cell sales. |
| Providing access to electricity: Na = number of households / total number of people having now access to the electricity produced by a 1 MW plant, and who would not have such access if another type of plant were to be built (grid connected). | Recall : we have chosen in the study to focus only on grid-connected plants. In developing countries isolated PV modules may bring power to peopl who may not, otherwise, have access to electricity a all without them |
| - Industrial Safety Accident Rate: SAR = number of accidents for all utility personnel permanently assigned to the plant (contractor personnel not included), that result in one or more days away from work (excluding the day of the accident) or one or more days of restricted work (excluding the day of the accident), or fatalities, per 1,000,000 man-hours worked. | This indicator is already widely used for othe conventional types of power plants (nuclear, fossil fired, etc) The purpose of this indicator is to monitor progress in improving industrial safety performance for all utility personnel permanently assigned to the utility's staff. This indicator was chosen as the personnel safety indicator over other indicators, such as injuty rate or severity rate, because the criteria are clearly defined utilities currently collect this data, and the data are the least subjective. |
| * ENEL Cesi Renewable Unit at http://www. | eet, London ŴI R 6LE, UK. 734 5926 E-mail: info@worklenergy.org cesi.it el : β9) 02 2 125 5674 Fax : (39) 02 21 25 5480 |



Other general information must of course be provided for further analysis and fair comparisons : plant size, cycle of operation, age, vintage, etc ... Life time and return time (number of years of production of electricity needed for implementation of the plant) should also be provided when available.

Definitions and typical (US) values

The following table recalls the performance indicators proposed for biomass energy, with their definitions and examples of typical values obtained in the USA, from 68 US power plants giving typical, low and high values of these indicators. These plants range up to 55 MW producing steam, electricity or both in cogeneration, and use either virgin wood, agricultural, animal, urban or other wood wastes.



| Technical Indicator | Units | Definition | Typical Value | Low Value | High Value |
|-------------------------------------------------------------------------------------------------|--------------|---------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|--------------------------|---------------------------|
| Size ⁽¹⁾ | MWe | Plant size in net power output | 25 | 8 | 65 |
| Generation | GWh/ year | Total electricity (net) generation per year | 153.3 | 35.04 | 455.52 |
| Capacity factor (annual) | | Total net electricity generation per year divided by plant size in net MW times the 8760 hrs in a year | 0.700 | 0.500 | 0.800 |
| Hours per year equivalent of the capacity factor (if run at full power) ⁽³⁾ | hours | Number of hours that would give the net annual generation if all operation were at full net size of plant | 6132 | 4380 | 7008 |
| Efficiency (higher heat value) | | Net output in heat unit equivalent of the electricity divided by the fuel heat input using the higher heating value of the fuel | 0.201 | 0.155 | 0.263 |
| Heat Rate (SI units) | MJ/kWh | Fuel heat input per net electricity output | 18 | 13.5 | 23 |
| HHV Higher heating value (at moisture & ash free) ⁽⁴⁾ | MJ/kg | Heat content (HHV basis) if there were no moisture and no ash | 19.7 | 18.6 | 20.9 |
| Fuel ash content on dry basis | % | Fraction of the total fuel input by weight (dry, not as- received, basis) that is ash | 2% | 1% | 10% |
| Dry Higher heating value (at ash given, but no moisture) | MJ/kg | Heat content (HHV basis) if there were no moisture, at ash given | 19.3 (2% ash) | 17.7 (10% ash) | 19.5 (1% ash) |
| Fuel moisture ⁽⁵⁾ | % | Moisture (H2O) as a fraction of the total weight of fuel (wet, not dry basis) | 30% | 10% | 60% |
| Wet Higher heating value (at moisture given, typical 2% ash) | MJ/kg | HHV at typical 2% ash content, at moisture given | 13.5 (30% moisture) | 7.7 (60% moisture) | 17.3 (10% moisture) |

Remarks:

- (1) *Size* : in general, biomass plants tend to be small rather than large. They can be as low as a few hundred kWe, but the more realistic ranges from a few MW to 25 or 40 MW. 65 MW is rather large.
- (2) *Capacity factor*: this can reach 90%.
- (3) Hours per year equivalent of the capacity factor (if run at full power): it can reach 7800 hours/year.
- (4) LHV (Lower Heating Value, or lower calorific value) is also used, especially in gasification. Usually LHV is 94% of HHV for biomass, so efficiency on LHV basis is 6% higher than on HHV basis.
- (5) *Fuel moisture*: general typical values range from 5-10% to 50%. Anything over 50% moisture creates too many problems. Bagasse for example has traditionally been used at 50% moisture content.





Additionnal possible indicator: the average distance of transportation of fuel (wood, ...) to the plant can also be an interesting indicator, in terms of additional pollutants emitted during the transportation.







 Due to the importance of highlighting the effects of Planned/Forced Outages, two separate Availability Factors must be determined, including or excluding the time lost during the Planned Outage with respect to the actual operating hours.

 Steam Availability Factor =
 Average steam flow (t/h) during period x 100

Steam Supply (t/h)

An alternative definition of Steam Availability Factor could derive from the following consideration: some generation may be lost due to a shortfall in steam supplied from the steam-field; measuring the steam supply at the turbine inlet (t/h), thus: Steam Availability Factor = [(Steam Supply)-(Steam Production Shortfall)]x100 Steam Supply (t/h)

The following examples show data collected from some typical power plants : **Sample Applications** 1999 1999 1/4/97 - 31/3/98 Year Year Year Installed Capacity 60 MW Installed Capacity 20 MW Installed Capacity 50 MW 17 MW 48 3 MW Maximum Load 55 MW Maximum Load Maximum Load Annual Produced Electricity 462845 MWh 142248 MWh Annual Produced Electricity Annual Produced Electricity 361651 MWh Hours of Operation 8748 hrs Hours of Operation 8443 hrs Hours of Operation 8112 hrs **Capacity Factor** 88.1 % **Capacity Factor** 81.2 % **Capacity Factor** 82.6 % Load Factor 96.1 % Load Factor 95.5 % Load Factor 85.5 % **Availability Factor** 99.9 % **Availability Factor** 96.8 % **Availability Factor** 92.6 % Italian Plant nº 2 (20 MW) Italian Plant nº 1 (60 MW) Japanese Plant (50 MW) ed WEC Working Group on the Performances of Generating Plants (PGP)

Definitions of specific terms

Geothermal Power Facility

The main components of a Geothermal Power Facility are:

- a) a number of wells to tap terrestrial heat from underground by means of a carrier fluid (steam, and/or hot water, and/or hot brine);
- b) a gathering system of such fluid;

Production Area

- c) a power plant to use the heat of the carrier fluid for electricity production;
- d) a condensed water, or residual water, or separated brine re-injection system.

The actual net electrical output of the plant results from interactions among these components. In general, we have:

[geothermal power facility] = [production area] + [power plant]

In general, the Production Area of a geothermal field with conditions favourable for the generation of electric energy is usually formed by: i. a group of production and reinjection wells;

- ii. a steam/water, or steam/brine separation plant;
- iii. a steam, or steam/water, or steam/brine separation plant,
- a steam condensate, or residual water, or separated brine reinjection system;
- a steam condensate, or residual water, or separated of the reinjection syste
 a steam venting system to cope with emergency situations;
- vi. the control equipment associated with each of these components, which is needed to
- operate the Production Area in appropriate and safe conditions.

A Production Area is complete when it is capable of yielding the carrier fluid in the quantities and of the quality required to supply the associated Power Plant at its maximum output. All waste fluids are either reinjected into the underground for re-heating by terrestrial heat flow and steam regeneration or disposed in an environmentally sound manner.

• Power Plant

The Power Plant consists of single or multiple generating units including: steam or binary turbine, generator, condenser, cooling system, generator transformer, gas extraction system and all associated electrical control equipment. It is connected to the geothermal steam/brine supply system.

Installed Capacity

The Installed Capacity (in MWe) is the reference value for the power plant, set by the manufacturer as its target output, when the plant is operating at its design conditions.

Possible reserve units should not be considered as part of the installed capacity, but can be accounted for in a separate list.

Maximum Load

The Maximum Load (in MW_e) is the highest average value over one hour from the power plant as measured at the generator transformer supply voltage terminals, when operating at its stated design conditions or adjusted to point conditions. It can also be denominated as «Running Capacity» or «Maximum Net Deliverable Capacity».

Annual Produced Electricity

The Annual Produced Electricity is the electricity annually generated by the power plant during the observation time (in MWh). This electric output is measured at the generator transformer supply voltage terminals.

Design Conditions

The power plant is designed for a specific range of operating conditions. Natural modifications of the geothermal fluid conditions, in terms of pressure, temperature and gas content, can alter the net output from the plant. Power factor, cooling water or ambient air temperatures (seasonal effects) are also specified design conditions, and often the plant operates with these parameters. The electric output should be corrected to account for the above-mentioned deviations.

Planned Outage

A Power Plant or Production Area Outage that has been scheduled well in advance (at least two weeks), and is included in the annual plant outage programme.

Forced Outage

A Power Plant or Production Area Outage that requires the plant to be taken out of service immediately or before the next planned outage.

• Steam/Brine Production Shortfall

Condition under which the Steam/Brine production capacity of the geothermal wells is unable to meet the power plant required steam rate. • Steam/Brine Supply

Steam/Brine Supply is the average steam plus non-condensable gas mass flow (in t/h) delivered to the turbine and gas extraction system to enable the turbine to achieve its Maximum Load.

Specific Steam/Brine Consumption

The Specific Steam/Brine Consumption is defined as the ratio of Steam/Brine Supply to Maximum Load.









ANNEX 4

PERFORMANCES OF RENEWABLE ENERGIES : SYNTHESIS OF THE DATABASES EXISTING OR UNDER PROGRESS

<u>Summary :</u>

In order to enable people to compare themselves and improve their performances, the availability of performance databases is necessary. This has been done for many years by WEC PGP for nuclear and fossil-fired power plants, and it continues through PGP Work Group 2 "*Power Plant Availability Statistics*", in charge of the collection and input of power plant performance data into the WEC PGP database.

As far as RES are concerned, we have investigated (mostly through Internet search and discussion with specialists) the databases that already exist or are under development throughout the world. The idea is to try, at least in a first step, to privilege collaborations with existing (and well-chosen) experiences, rather than trying to set up from this point on, new specific WEC PGP databases.

The following presents the databases that we have found. It seems that performance databases, as we should conceive them, **only exist today**:

- for Wind through the **Wind Stats** Newsletter.
- for Photovoltaics through the International Energy Agency (IEA-PVPS Task 2).

A database is **under construction** at NERC USA for wind (GADS – co-ordinated by Mike Curley, chairman of WEC PGP WG2).

Other RES databases exist, but they are not specifically devoted to the performance of the plants. It

seems in fact that, due to hard competition, people hesitate to provide information on their performances

If the aim of PGP is to set up databases for RES, as it was done in the past for more "classical" power plants, our proposal is that WEC officially contacts the people in charge of these databases (see contacts hereunder), and offers to collaborate with them in order to complete and improve the work already done within these existing databases and by PGP WG3. If it appears that such fruitful collaborations are possible, specialists of each type of RES should be nominated within WEC PGP to operate these collaborations.

Wind

• Existing performance databases:

It seems that only one database exists and is running today for wind. The results are presented every month in the publication **WindStats Newsletter**. It is mostly devoted to the European wind farms, but some data is given from other parts of the world (USA, New Zealand...). Unfortunately, no data is collected on the corresponding wind characteristics. Also, no data is available on environmental or sociological aspects.

More can be found on their web site (<u>windstats.com</u>). **Contacts**: <u>Windstats@forlaget-vistoft.dk</u>

Performance databases under preparation:

NERC (North American Electric Reliability Corporation) is presently setting up a new **GADS** database within **WTWG** (Wind Turbine Working Group), mostly intended to North American data. Mike Curley, chairman of WEC PGP WG2, is in charge of this new initiative.

Contact: <u>Mike.Curley@nerc.net</u>

• Databases on wind characteristics:

If performance databases are rather few, data on wind characteristics are more numerous. We can

mention the following web sites :

 <u>www.winddata.com</u>: this web site of annex XVII of IEA Wind provides data on wind speeds, directions and turbulence, measured for various sites in various countries. Some of them are directly measured on wind farms.

Contact : RISØ National Laboratory, admin@winddata.com

- <u>swera.unep.net</u> : the web site of SWERA provides data and maps of wind and sunshine in various countries (Brazil, Bangladesh, Kenya.).

Contact : <u>UNEP/DTIE-Energy/SWERA</u>

- <u>www.awstruewind.com</u> : AWS TrueWind is an organisation specialised in the technical applications of renewable energies and proposes some wind maps (with private access).

Photovoltaics

• Existing performance databases:

Only one database has been found on the **performances** of photovoltaics: **IEA PVPS-Task2** has prepared in 2000 a report of the International Energy Agency which provides an international database on the performances of PV systems operating in about many countries around the world (Austria, USA, France, Germany, Italy, Israel, Japan, Netherlands, Switzerland,...). The report can be found on <u>www.iea-pvps-task2.org</u>. The current database (version of June 2005) contains data of 431 monitored PV plants and would probably be a very good basis for a perennial database.

Contact : Institut für Solarenergieforschung GmbH – Hameln / Emmerthal

• **Other web sites** give information and data on PV, but they mostly concern **characteristics** of PV systems, not their performances:

- <u>www.photonnes.de</u> : statistics on PV installed capacity and produced electricity in Germany
- <u>swera.unep.net</u> : see wind § up there
- <u>http://re.jrc.cec.eu.int/pvgis/pv/</u> : this site of the European Commission (Joint Research Centre) provides, for every point (latitude, longitude) in Europe, Africa and South West Asia, maps and values of monthly sunshine, temperature, or optimal inclination of solar panels.
- <u>eosweb.larc.nasa.gov/cgi-bin/sse/sse.cgi?na</u> : this site proposes NASA meteorology and solar energy data for every point (latitude, longitude) in the world.
- Some other databases and payable reports seem to be available on:
- <u>www.pvenergy.com</u> : PV Energy System proposes a report on the technologies, costs and performances of PV systems (« PV Technology, Performance, Cost 1995-2010 »,).
- <u>www.solarbuzz.com</u> : Solarbuzz proposes the same kind of product as PV Energy System (« Marketbuzz 2006 »).

Geothermal energy

No clear and efficient performance database on geothermal energy has been found. Projects are under way but nothing seems to be realised today. We can however mention:

• <u>iga.igg.cnr.it</u> : the International Geothermal Association has made the inventory, country by country, of the installed powers and capacity factors.

Contacts: IGA Secretariat at <u>iga@samorka.is</u> We can notice in particular an article <u>http://iga.igg.cnr.it/pdf/WGC/2005/1708.pdf</u> reporting the existence of a database on geothermal energy in the Philippines.

 <u>www.iea-gia.org</u>: the reports of the annex 7 of IEA Geothermal mention a project of international database on the performances and costs of drilling.

<u>Biomass</u>

No general database on the performances of biomass has been found, but **some inventories limited to a given technique** can be found, in particular about gasification:

- <u>www.gasifiers.org</u>: this site makes the inventory of the gasification plants existing throughout the world. It details, unit by unit, the produced electricity, characteristics of the system, used fuels, emissions, number of hours of production per year, …
 Contact: info@gasifiers.org or BTG biomass technology group
- <u>www.woodgas.com/gdatabase.htm</u>: this site also makes the inventory of the gasification plants but provides less information than the previous web site.

Some other web sites also provide very complete data on the composition of the fuels, ashes, ...:

• <u>www.ieabcc.nl</u> : the databases of the IEA Bioenergy Task 32 give the composition of:

the fuels (<u>www.ieabcc.nl/database/biomass.php</u>), the ashes (<u>www.ieabcc.nl/database/ash.php</u>) and

the fumes (www.ieabcc.nl/database/condensate.php)

for various types of fuels. A database providing the characteristics of the co-combustion plants installed throughout the world is also available (<u>www.ieabcc.nl/database/cofiring.php</u>) but no performance data are included.

Contact: complete list of members available on <u>www.ieabcc.nl/taskmembers.html</u>

- <u>www.vt.tuwien.ac.at/biobib</u> : this database gives the composition of any type of fuel (with details according to the species of plants) as well as those of their ashes ; however it seems that this database is mostly focused on biofuels.
 Contact: Technological University of Vienna
 - Contact. reenhological Chiversity of Vienha
- <u>www.ecn.nl/phyllis</u> : Phyllis is also a database including the composition of fuels (wood, wastes), but it enables to get the characteristics of a mix of fuels (humidity, ashes ...) as well.
 Contact: <u>biomass@ecn.nl</u>, Energy research Centre of the Netherlands
- <u>www.woodgas.com/proximat.htm</u> : woodgas also proposes this type of data, as well as information on gasification.

We can also mention <u>www.epa.gov/landfill/proj/index.htm</u> which collects the US units functioning with gas due to the decomposition of wastes (capacity and avoided CO2, but no other performance data).

Other RES databases

A few other general databases on RES exist, but none seems really satisfactory for our present

purpose. Anyway hereunder are some web sites which could be worthwhile:

- <u>www.enerdata.fr</u> : ENERDATA proposes many databases in the field of energy, among which ODYSSEE which seems to be the most interesting. It gathers data on energy efficiency and on CO2 indicators for the European countries.
- <u>www.vgb.org/kissye.html</u>: operated by VGB, KISSYE gathers statistics on the performance indicators of power plants. However it seems to be restricted to Germany and only to fossil-fired, nuclear and co-generators. The big wind farms will probably soon be integrated.
- <u>www.caddet.org</u>: CADDET provides a lot of information on the technologies used for renewable energies. InfoStore in particular is a database of projects sometimes containing technical or performance data. Unfortunately InfoStore is not standardised and has no precise performance indicators. This database could however be useful for a specific precise project.
- <u>www.nrel.gov/analysis/repis</u> : REPiS is a US database providing information on the RES plants. Unfortunately we could not find anything on RES performances, except installed capacity.

Conclusion

In spite of the present enthusiasm for renewable energies and the large number of Internet sites dedicated to them, very little available and useable performance data exists.

The manufacturers, countries and various organisations obviously prefer to communicate on the installed capacities rather than on the real efficiency and performances of the plants.

Finally, only two already existing databases seem satisfactory to us: Windstats for wind farms and IEA-pvps-task2 for Photovoltaics. NERC GADS database in preparation for wind would also be a good basis, provided it extends beyond North America.

Algeria Argentina Australia Austria Bangladesh Belgium Botswana Brazil Bulgaria Cameroon Canada China Congo (Democratic Republic) Côte d'Ivoire Croatia Czech Republic Denmark Egypt (Arab Republic) Estonia

India Indonesia Iran (Islamic Republic) Iraq Ireland Israel Italy Japan Jordan Kenya Korea (Republic) Kuwait Latvia Lebanon Libya/GSPLAJ Lithuania Luxembourg Macedonia (Republic) Mali Mexico

Peru Philippines Poland Portugal Qatar Romania **Russian Federation** Saudi Arabia Senegal Serbia Slovakia Slovenia South Africa Spain Sri Lanka Swaziland Sweden Switzerland Syria (Arab Republic) Taiwan, China

Member committees of the World Energy Council

Ethiopia Finland France Gabon Georgia Germany Ghana Greece Guinea Hong Kong, China Hungary Iceland Monaco Mongolia Morocco Namibia Nepal Netherlands New Zealand Niger Nigeria Norway Pakistan Paraguay

Tajikistan Tanzania Thailand Trinidad & Tobago Tunisia Turkey Ukraine United Kingdom United States Uruguay Yemen.

| World Energy Council Regency House 1-4 Warwick Street London W1B 5LT United Kingdom T (+44) 20 7734 5996 F (+44) 20 7734 5926 E info@worldenergy.org www.worldenergy.org | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| Promoting the sustainable supply and use of energy for the greatest benefit of all ISBN: [Insert ISBN here] | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |